

Alipurduar University

P.O. Alipurduar Court, Dist Alipurduar, Pin736122

Dated 17.04.2025

eNotice Invitinge-Tender - NIT02/APDU/R/2025-26.

e-T enders are invited from reputed Vendors for supply and installation of Split air conditioner in the Alipurduar University, P.O. Alipurduar Court, Dist. Alipurduar, PIN- 736122. For details please visit https://wbtenders.gov.in.

Sl. No.	Item	Earnest Money	Completion Time
1	As Per Annexure-I	20000.00	15 days from the date of issuance of work order

TERMS AND CONDITIONS:

- **1.** The base price and GST shall be shown separately.
- **2.** Taxes will be deducted at source as per prevailing rules of Central and State Government.
- **3.** The terms and conditions of payment shall be declared clearly.
- **4.** Copy of current year Trade License, PAN card, GST registration certificate shall be accompanied with the technical bid documents. [Non Statutory Documents]
- **5.** The vendor shall provide Company details as per Annexure-II.
- **6.** The vendor shall submit authorization certificate from OEM.
- **7.** The vendor shall have credential of supply of Air Conditioner in any University / institution / Govt. Organization. Copy of credential certificate shall be submitted along with technical bid (Non Statutory documents).
- **8.** The vendor shall clearly state the pre-installation requirements and take all responsibilities to arrange the same.
- **9.** The Air Conditioner shall carry minimum 1 (One) year onsite warranty from the date of installation.
- **10.** The service engineer shall attend the call within 24 hrs for trouble shooting to be done on no wait basis.
- **11.** The successful tenderer shall complete the installation of Air Conditioner within 15 (Fifteen) days from the date of issuance of the supply order.
- 12. Approximate no of requirement of 2 ton capacity Air Conditioner maybe 20 & 1.5 ton capacity Air conditioner maybe 7.
- **13.** A sum of Rs. 20,000/- shall be deposited to the under noted account of the University as earnest money and the copy of receipt challan of NEFT / RTGS with UTR number shall be accompanied with the technical bid document (Statutory Documents) failing which the tender paper will be treated as cancelled. The earnest money of the unsuccessful quotationer (s) will be refunded without interest after one month of the opening of tender paper and the same of the successful candidate will be refunded without interest after three months of the satisfactory installation of the Air Conditioners subject to redressed of complaint, if any.

Name of the A/c: Alipurduar University

Account Number: 39902163065

IFSC Code: SBIN0000005

- **14.** The University authority reserves the right to accept or reject any/all quotations.
- **15.** The quotation should be valid upto 31.10.2025.
- **16.** The vendor shall quote for all the items.
- **17.** The brochure / catalogue of the Air Conditioner shall accompany the technical bid documents (Non Statutory documents).
- **18.** Selection of the agency will be made on the basis of both technical and financial bids. Technical bids and financial bids shall be submitted by online only. Offline submission of tender paper will not be accepted.
- **17.** 92% of the total or devalue shall be released after the successful installation / commissioning of the equipment against the submission of the test report duly certified by the concerned authority. The remaining 8% of the bill value shall be deducted and kept aside as security deposit which will be paid after 3 (three) months from the date of satisfactory installation, subject to redress of complaints ,if any
- **18.** The last date of submission of tender form is up to **05.05.2025** at 3.00 P.M. and to be opened on 07.05.2025 at 3.00 PM.
- **19.** All cases of disputes not covered under the terms & conditions of Tender will be referred to the Vice-Chancellor for a decision which shall be final and binding on both the parties.
- **20.** For any clarification regarding tender please contact with Sri Baturam Sarkar, State Officer incharge, Alipurduar University. (Tel. No. 8250788768)
- 21.It maybe noted that the work order for installetion of Air Conditioners will be issued after receiving the financial and admistrative approval/grants from the competent authority, Department of Higher Education, Govt. of W.B.
- 22. Date & Time Schedule

SINO	Particulars	Date&Time
1	Publishing of Tender	19.04.2025
2	Documents download / sell start date (Online)	19.04.2025 FROM 10.00 A.M.
3	Bid submission Start Date	19.04.2025 FROM 10.00 A.M.
4	Bid Submission End Date	05.05.2025 UPTO 3.00 P.M.
5	Technical Bid Opening	07.05.2025 AT 03.00 P.M.
6	Offline Submission	NO OFFLINE SUBMISSION WILL NOT BE ACCEPTED
7	Financial BidOpening	To be notified

BIDDERS DETAILS

(To be provided on company letterhead)

NIT	NO.:	
TEN	DER	ID:

1	NAME OF THEBIDDER	
2	ADDRESS	
3	CONTACT NUMBER	
4	CONTACT PERSON	
5	EMAIL ID	
6	BANK DETAILS Account Name Account Number Name of the Bank Name of the Branch IFSC	

Authorized Signatory (with seal & Stamps)

Technical Specifications of 1.5 ton inverter AC

Star Rating 5 Rated Cooling Capacity: Full Load 4000 Rated Cooling Capacity: Half Load 2000 Rated Cooling Power: Full Load 1010 Rated Cooling Power : Half Load 450 **Power Supply**

Air Flow Volume - Indoor Noise Level - Indoor Operation

Compressor Type

Wide Operating Voltage Range Max operating Ambient Temp Range

Refrigerant Gas

Indoor Unit Dimension (WxHxD) Indoor Unit Net / Gross Weight Outdoor Unit Dimension (WxHxD)

Outdoor Unit Net / Gross Weight **Connecting Pipe**

Condenser Coil

Filter

Evaporator Fin LED Display Self Diagnosis **Auto Restart** Sleep Mode **Dual Temp Display**

230 / 50 / 1 Phase

770 46

LCD Remote

High EER Rotary - BLDC

145-270 52'C R32

80x29.2x22.2 9.3/12.0

83.5 **X** 55.5 **X** 29.5

27.2/31.8

Cu-Cu(12.5mm & 6.35mm)

Copper

Triple Filter Protection

Blue Yes Yes Yes Yes Yes

Technical Specifications of 2 ton inverter AC

Star Rating 5

Power Supply 230 / 50 / 1 Phase

Air Flow Volume – Indoor 1750 Noise Level – Indoor 46

Operation LCD Remote

Compressor Type High EER Rotary – BLDC

Wide Operating Voltage Range
Max operating Ambient Temp Range
Refrigerant Gas

145-270
52'C
R32

Connecting Pipe Cu-Cu(12.5mm & 6.35mm)

Condenser Coil Copper

Filter Triple Filter Protection

Evaporator Fin Blue
LED Display Yes
Self Diagnosis Yes
Auto Restart Yes
Sleep Mode Yes
Dual Temp Display Yes
Swing 2 way